

NOTES

1. E-STOP STATIONS SHALL BE MANUFACTURED OF 316L STAINLESS STEEL.
2. E-STOP STATIONS SHALL BE MOUNTED ADJACENT TO ALL MOTORS (AT LEAST AN ARMS LENGTH AWAY). THE FINAL POSITIONS OF THE E-STOP STATIONS WILL BE CONFIRMED ON SITE BY THE ENGINEER PRIOR TO CONNECTING THE WIRING.
3. MANUFACTURING DRAWINGS OF THE E-STOP STATIONS SHALL BE SUBMITTED TO THE ENGINEER FOR APPROVAL PRIOR TO MANUFACTURING.

REV	DESCRIPTION	DATE	REV BY	CHKD
A	ISSUED FOR TENDER	15/11/16	JJK	AB
REVISIONS				

DESIGNED	A BRAND
DRAWN	JJ KING
CHECKED	A BRAND
APPROVED	
PROJ. PRINCIPAL:
SIGNATURE: DATE:




Royal HaskoningDHV
Enhancing Society Together

PO Box 5195
TYGER VALLEY
7536

Tel: (021) 936 7600
Fax: (021) 936 7611
Email: capetown@rhdhv.com

CLIENT



PRINCE ALBERT MUNICIPALITY

PRINCE ALBERT UPGRADING OF WWTW				
TYPICAL E-STOP STATION				
PROJECT No.	TENDER No.	SCALE	DRAWING No.	REV
MD2608-100-101	3/2017	N.T.S.	MD2608-E-022	A