# MUNISIPALITEIT PRINS ALBERT

Rig alle korrespondensie aan: Address all DIE MUNISIPALE BESTUURDER THE Privaatsak X53, Prins Albert, 6930 Private Bag E-Pos / E-Mail <u>adminklerk@pamun.gov,za</u> Tel:



## MUNICIPALITY VAN OF PRINCE ALBERT

correspondence to: MUNICIPAL MANAGER X53, Prince Albert, 6930 023-541 1036, Fax: 023-541 1321

> Ashley America Manager: Infrastructure Services Prince Albert Municipality

#### **ATTENTION: ALL TENDERERS**

### TENDER No: 54/2021: LEEU GAMKA MAINTENANCE OF THE REVERSE OSMOSIS AND ULTRA-FILTRATION WATER TREATMENT PLANT

#### ADDENDUM No. 1:

No	Description
1.	QUERIES
1.1	Query 1: Please can you identify how many of each replacement membranes are needed for the first and second stages of the RO?
	Response: 6- Stage One and 6-Stage 2
1.2	Query 2: Please can you also identify the diameter of valves that potentially need to be replaced?
	Response: 80mm W DI Body ButterflyValve
1.3	Query 3: There is no information in the tender about any of the instrumentation that needs replacing. With no information we can't provide an accurate price. Please can you provide me with an instrumentation schedule.
	Response: Find attached additional data sheets for Instrumentation along with diagrams
1.4	Query 4: Would it be possible to arrange a site visit?
	Response: Yes. Atleast 24 hours in advance.

